

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48961

1. OWNER Gordon + Deborah Denny ADDRESS AND WELL LOCATION 121 Surandon Ln  
Reserve Calif 95872 Lat 29 Surandon In  
Smith Valley Nev 89430  
 2. LOCATION SF 1/4 N E 1/4 Sec 36 T 12 N/S R 23 E County  
 PERMIT NO. 010-151-06 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy loam top soil</u>		<u>0</u>	<u>22</u>	<u>22</u>
<u>sandy coarse + fine sand</u>	<u>yes</u>	<u>22</u>	<u>35</u>	<u>13</u>
<u>blue clay + black sand sulfur smelt</u>		<u>35</u>	<u>62</u>	<u>27</u>
<u>gray clay</u>		<u>62</u>	<u>132</u>	<u>70</u>
<u>sand</u>	<u>yes</u>	<u>132</u>	<u>265</u>	<u>133</u>
<u>gray + green clay</u>		<u>265</u>	<u>285</u>	<u>20</u>
<u>sand + coarse sand</u>	<u>yes</u>	<u>285</u>	<u>335</u>	<u>150</u>
<u>clay blue</u>		<u>335</u>	<u>360</u>	<u>35</u>
<u>clay blue</u>		<u>360</u>	<u>365</u>	<u>5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 365 Feet Depth Cased 365 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 0 Feet To 50 Feet  
6 5/8 Inches 50 Feet 365 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>188</u>	<u>0</u>	<u>365</u>

Perforations:  
 Type perforation Harley saw slott  
 Size perforation 1/16 x 3/32  
 From 340 feet to 365 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 70 F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Mills Drilling  
 Address P.O. Box 92 Smith  
Nev. 89430  
 Nevada contractor's license number 32166 A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718  
 Signed Edmund Mills  
 By driller performing actual drilling on site or contractor  
 Date Jan 22 - 05

Date started Nov 25 - 04 2004  
 Date completed Jan 22 - 05 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>15</u>	<u>20</u>	<u>3 hrs</u>