

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 95770
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **28186**

1. OWNER **CHARLES PIERCE**
 MAILING ADDRESS **4171 W JACOB ST**
PAHRUMP, NV

ADDRESS AT WELL LOCATION **4171 W JACOB ST**

2. LOCATION NE 1/4 NE 1/4 Sec. 23 T 20S
 PERMIT NO. 41-432-06
Issued by Water Resources Parcel No.

N/S R 52E E NYE County
GOLDEN SPRING RANCH UNIT 2
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CALICHE	WB	178	189	11
CLAY		189	200	11
CLAY		0	16	16
CALICHE		16	30	14
CLAY		30	60	30
CALICHE	WB	60	73	13
CLAY		73	120	47
CALICHE	WB	120	131	11
CLAY		131	152	21
CALICHE	WB	152	160	8
CLAY		160	178	18

DCNR/DWR RECEIVED

APR 05 2005

LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
 From 0 Feet To 200 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
 Type perforation **SAWCUT**
 Size perforation **1/8 X 3**
 From 140 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor
 Address **P.O. BOX 4220** Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**
 Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **3/29/2005**

Date started 3/28/2005, 19____
 Date completed 3/28/2005, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)