

OFFICE USE ONLY
Log No. 95798
Permit No. _____
Basin 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54724

1. OWNER Jim Perry ADDRESS AT WELL LOCATION 249 Hwy 95A
MAILING ADDRESS Yerington NV 89447

2. LOCATION SE 1/4 NE 1/4 Sec 28 T 15 N R 25 E Lyon County
PERMIT NO. 14-111-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>White clay + sand</u>		<u>0</u>	<u>30</u>	
<u>Brown clay</u>		<u>30</u>	<u>60</u>	
<u>course sand</u>		<u>60</u>	<u>70</u>	
<u>Brown gravel</u>		<u>70</u>	<u>100</u>	
<u>gray clay</u>		<u>100</u>	<u>120</u>	
<u>Brown clay & coarse brown sand</u>		<u>120</u>	<u>140</u>	

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 0 Feet 140 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 1/2</u>		<u>1 5/8</u>	<u>1</u>	<u>140</u>

Perforations:
Type perforation factory milled
Size perforation 3/32
From _____ feet to _____ feet
From _____ feet to _____ feet
From 120 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow NA G.P.M. _____ P.S.I.
Water temperature 60 °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Contractor
Address Box 599 Silver Springs NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed Scott Enke
By driller performing actual drilling on site or contractor
Date 10-22-04

Date started 10-21, 2004
Date completed 10-22, 2004

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>	<u>80</u>	<u>2 Hrs</u>

RECEIVED
05 JAN -4 AM 11:03
STATE ENGINEERS OFFICE