

OFFICE USE ONLY

Log No. 95799  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27890

1. OWNER Caesars Palace ADDRESS AT WELL LOCATION Same as Owner  
 MAILING ADDRESS 3570 Las Vegas Blvd. Las Vegas, NV 89109  
 2. LOCATION SE 1/4 SE 1/4 Sec. 17 T. 21 N. R. 61 E. Clark County  
 PERMIT NO. 162-17-810-007 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravelly Sand</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>Caliche</u>		<u>8</u>	<u>12</u>	<u>4</u>
<u>Gravelly Clay</u>		<u>12</u>	<u>19</u>	<u>7</u>
<u>Gravelly Sand</u>		<u>19</u>	<u>25</u>	<u>6</u>
<u>Clay</u>		<u>25</u>	<u>35</u>	<u>10</u>

**DCNR/DWR RECEIVED**  
**APR 05 2005**  
**LAS VEGAS OFFICE**

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 0 Feet 35 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>SC440</u>	<u>PVC</u>	<u>0</u>	<u>15</u>

Perforations: Factory Slotted  
 Type perforation \_\_\_\_\_  
 Size perforation .020  
 From 15 feet to 35 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 13  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 13 feet to 35 feet

Date started 1-26, 2005  
 Date completed 2-2, 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 21 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WDE Exploration & Wells Contractor  
 Address 570 Corinthian Way N. Las Vegas, NV 89030 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0012852  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 2057  
 Signed [Signature] by driller performing actual drilling on site or contractor  
 Date 4-1-05