

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY  
 Log No. 95809  
 Permit No. \_\_\_\_\_  
 Basin 893

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52252

1. OWNER Vince Cannizaro  
 MAILING ADDRESS 2665 Cactus View Dr.  
Reno, NV 89506

ADDRESS AT WELL LOCATION Serpentine Rd. Antelope Valley

2. LOCATION SW 1/4 NW 1/4 Sec. 14 T 22N  
 PERMIT NO. 079-481-56  
Issued by Water Resources Parcel No.

N/S R 19E E Washoe County  
 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 Now Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Sandy brown clay		1	4	3
Fine brown sand				
w/gravels		4	16	12
Cemented sands & gravels		16	53	37
Soft zone		53	55	2
Sandy brown clays		55	93	38
Soft zone		93	96	3
Sandy brown clay		96	141	45
Soft zone		141	144	3
Brown sandy clay		144	193	49
Soft zone	x	193	196	3
Brown sandy clays		196	216	20
Soft zone	x	216	219	3
Brown sandy clays		219	232	13
Soft zone	x	232	241	9
Brown sandy clays		241	250	9
Brown sandy clay	x	250	275	25

8. WELL CONSTRUCTION

Depth Drilled 275 Feet Depth Casod 275 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0	57
9 7/8 Inches	57	275

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1.5	275

Perforations:  
 Type perforation Factory  
 Size perforation 3/32 x 3"  
 From 220 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 57  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 57 feet to 275 feet

Washoe Co. Permit #040302

RECEIVED  
 OFFICE - 8 AM 10:53  
 STATE ENGINEERS OFFICE

Date started 1/31/2005, 19  
 Date completed 2/4/2005, 19

9. WATER LEVEL

Static water level 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Not Tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bruce MacKay Pump & Well Service, Inc.  
 Contractor  
 Address 1600 Mt. Rose Hwy  
 Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed R. Bruce Mackay  
 By driller performing actual drilling on-site or contractor  
 Date 2/7/2005

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Air	18		3 Hrs