WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95811
Permit No.
Basin 105

NOTICE OF INTENT NO: ~~54704~~ ~~[illegible]~~ 54704

1. OWNER Robert Gunnoe
MAILING ADDRESS 288 Fairmeadow St.
Henderson, NV 89012

ADDRESS AT WELL LOCATION 1963 Sheep Camp Rd.Gardnerville

2. LOCATION SW 1/4 SE 1/4 Sec. 1 T 12N N/S R 20E E Douglas County
PERMIT NO. (Issued by Water Resources) 1220-01-002-018 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6 5/8" water well. We perforated from about 160' to surface at four around with spider air perforator. We then pumped approximately 2 cu. yards of neat cement from bottom to top using tremmie pipe. Cement was mixed at 5.2 gallons/sack. We cut the casing off about 2' below grade.				

RECEIVED
05 FEB -8 AM 10:53
STATE ENGINEERS OFFICE

Date started 1/20/2005 , 19__
Date completed 1/27/2005 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 174 Feet Depth Cased 174 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	140
6 5/8	?	PVC 40	140	174

Perforations:
Type perforation Air perforator
Size perforation puncture
From 164 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 168 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2205
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 2/4/2005

USE ADDITIONAL SHEETS IF NECESSARY