WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95813
Permit No.
Basin 085

NOTICE OF INTENT NO. 52245

1. OWNER Jerry Hoffman- Eastlake Bar
MAILING ADDRESS P.O. Box 3404
Incline Village, NV 89450

ADDRESS AT WELL LOCATION 3050 Eastlake Blvd.

2. LOCATION NE 1/4 SE 1/4 Sec. 31 T 17N N/S R 20E E Washoe County
PERMIT NO. W575A/71544 (Issued by Water Resources) 050-419-08 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6 5/8" commercial water well that was 117' deep. Water level was 106'. We perforated from 105' to surface using a Mills Knife and cut 4 slots at 90 degree intervals and 1 foot vertical intervals. We then pumped 1.5 cu. yards of neat cement mixed 5.2 gallons/sack and used tremmie pipe to fill from the bottom to the top.				
Washoe Co. Permit #040333				

RECEIVED 05 FEB -8 AM 10:53 STATE ENGINEERS OFFICE

Date started 1/31/2005 , 19__
Date completed 1/31/2005 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 117 Feet Depth Cased 117 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	117

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 105 feet to Surface feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 117
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 106 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Not Tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 2/3/2005

USE ADDITIONAL SHEETS IF NECESSARY