WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45817
Permit No.
Basin 107

NOTICE OF INTENT NO. 54053

1. OWNER Martin Stearns & Monique
MAILING ADDRESS 79 Artistview Rd
Wellington 89444
ADDRESS AT WELL LOCATION 24 Yellow Sage
Wellington

2. LOCATION SE ¼ SE ¼ Sec. 12 T. 11 N N/S R. 23 E. Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 009-132-02 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.g. + gravel		0	80	
D.g. clay + gravel		80	120	
gray clay		120	200	
Brown + gray clay		200	240	
D.g. + gravel		240	255	
Brown clay		255	300	
D.g. coarse sand + gravel		300	320	

RECEIVED JAN 18 2005 STATE ENGINEER'S OFFICE

Date started 1-12-05, 20
Date completed 1-17-05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10+	200	
20+	240	

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 7/8 Inches	0 Feet	320 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	188	+1	20
6 5/8		SDR21	20	320

Perforations:
Type perforation Saw Cut
Size perforation 5/16
From feet to feet
From 280 feet to 290 feet
From feet to feet
From 300 feet to 320 feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60.0 °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address PX 599 Silver Springs (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed (By driller performing actual drilling on site or contractor)
Date 1-17-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627