WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95825
Permit No.
Basin 107

NOTICE OF INTENT NO. 54080

1. OWNER Richard & Sharlin Johnson
MAILING ADDRESS 23 Hawkview Rd
ADDRESS AT WELL LOCATION 23 Hawk View Wellington NV Hawk

2. LOCATION NW ¼ NW ¼ Sec. 12 T 11 N/S R 23 E Lyon County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. 10-221-09 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.g. + Clay		0	140	140 ft
gravel + coarse sand	*	140	160	20 ft
gray clay		160	220	60 ft
green + gray clay		220	260	40 ft
D.g. + clay		260	290	30 ft
D.g. + sand	*	290	310	20
Brown + gray clay		310	320	10
D.g. + gravel	*	320	335	15
Brown clay		335	340	5

Date started 12-29-04, 20
Date completed 1-6-05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+	200 ft	2 Hrs

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches Feet	Feet	
10 5/8 Inches 0 Feet	340 Feet	
Inches Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	188	+1	340
6 5/8		SDR21	20	340

Perforations:
Type perforation Sawcut
Size perforation 5/16
From 140 feet to 160 feet
From feet to feet
From 290 feet to 305 feet
From feet to feet
From 325 feet to 335 feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 60 feet to 340 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature COLD °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address BX 599 Silver Springs (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed (By driller performing actual drilling on site or contractor)
Date 1-6-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627