WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95831
Permit No.
Basin 026

NOTICE OF INTENT NO. 54726

1. OWNER Kim McCurry
MAILING ADDRESS 3136 Desert Shadows
ADDRESS AT WELL LOCATION Fernley NV

2. LOCATION SE ¼ SE ¼ Sec. 22 T. 20 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) | Parcel No. 02F-301-39 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobbles gravel + sand		0	100	
Brown clay + sand		100	120	
small gravel	+	120	130	
Brown clay		130	150	
gravel + sand	+	150	160	
~~[illegible]~~				
Red clay		160	180	
Sand + Boulders + gravel		180	200	
Brown + white + gray clay	+	200	230	
Coarse sand + gravel	+	230	250	
Brown clay		250	260	

Date started 11-22-04, 20
Date completed 11-30-04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
157	180	24 hrs

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	100 Feet
Inches		Feet	Feet
9⅞ Inches		100 Feet	260 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	13	188	+1	20
6		SDR21	20	260

Perforations:
Type perforation Saw cut
Size perforation 5/10
From 120 feet to 130 feet
From 150 feet to 160 feet
From 180 feet to 200 feet
From 230 feet to 250 feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 260 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60.0 °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address Box 599 Silver Springs NV (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-11-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627