

Log No. 95848  
 Permit No. \_\_\_\_\_  
 Basin 102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54720

1. OWNER Stambaert water corp ADDRESS AT WELL LOCATION Green St  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 SE 1/4 Sec. 1 T. 17N N/S R. 24 E Lyons County  
 PERMIT NO. 71332 17-073-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Clayey Sand</u>		<u>0</u>	<u>100</u>	
<u>Black granite clay</u>		<u>100</u>	<u>140</u>	
<u>Brown gravel + sand clay</u>		<u>160</u>	<u>180</u>	
<u>Brown gravel</u>		<u>180</u>	<u>190</u>	
<u>Brown gravel + clay</u>		<u>190</u>	<u>220</u>	
<u>Big gravel coarse sand</u>	<u>✓</u>	<u>220</u>	<u>250</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
7 7/8 Inches 200 Feet 250 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>19</u>	<u>150</u>	<u>1</u>	<u>200</u>
<u>6 5/8</u>	<u>13</u>	<u>188</u>	<u>150</u>	<u>250</u>

 Perforations:  
 Type perforation factory milled  
 Size perforation 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 230 feet to 250 feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 200 feet

Date started 10-11-04 20  
 Date completed 10-14-04 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50 +</u>	<u>220</u>	<u>1hr</u>
	<u>50 +</u>	<u>180</u>	<u>1 hr</u>
	<u>550</u>	<u>160</u>	<u>1hr</u>

9. WATER LEVEL  
 Static water level 109 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.0 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Lew Hossling Inc Contractor  
 Address Box 599 Silver Springs NV 89429 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 31841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-11-04

RECEIVED  
 JUN 10 2004  
 CIVIL ENGINEERS OFFICE