WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95857
Permit No.
Basin 108

NOTICE OF INTENT NO. 54739

1. OWNER Ray Greenberg
MAILING ADDRESS 8 Farrell LN
Yerington NV 89447

ADDRESS AT WELL LOCATION Yerington
51 E. Dobell Lane

2. LOCATION N ¼ NW ¼ Sec. 6 T. 13 N/S R. 26 E. Lyon County

PERMIT NO. Issued by Water Resources | 012-171-14 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Soil		0	7	
Cobbles, Sand		7	116	
Boulder, Cobbles		116	167	
Clay (DG)		167	84	
DG Cobbles		84	124	
w/Clay Seam				
Clay Seam		124	237	
w/Cobbles				
DG Cobbles		237	263	
DG Clay		263	299	
Some Cobbles				

RECEIVED JAN 25 2005 STATE ENGINEER'S OFFICE

Date started 12/15/04, 20
Date completed 12/18/04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8	4½ hrs	

8. WELL CONSTRUCTION
Depth Drilled 299 Feet Depth Cased 299 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		1 Feet	50 Feet
8 5/4 Inches		50 Feet	299 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	299
SDR21	PVC	(19' - 299)	SH	40

Perforations:
Type perforation Machine Perf
Size perforation 3/16 x 4 x 5# Round
From 204 feet to 298 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 299 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sean Drilling Inc Contractor
Address P.O. 599 Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 18716
Signed By driller performing actual drilling on site or contractor
Date 12/27/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627