

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27234

1. OWNER Steve McCrosky ADDRESS AT WELL LOCATION Junction of Highway 93 and 319 Panaca NV 89042
 MAILING ADDRESS PO Box 208 Panaca NV 89042

2. LOCATION SW 1/4 NW 1/4 Sec. 8 T. 2 N. R. 68 E. Lincoln County
 PERMIT NO. 6 12-170-56 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This was an old well 10' below ground surface in a cement celler. Customer brought casing to surface and filled in celler with dirt.				
Perforate with mills knife 0 to 73' as to specs. Drilled out clay-sand and boulders 73 to 100' using foam and polymer mud.				
OK well log said it was drilled to 100' originally and not cased to bottom. Installed 3" tremmie pipe and filled with Neat cement.				
Plugged both wells at same time using 600 gal water and 115 bags cement.				

DCNRP/DWR
RECEIVED
APR 11 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 73 Feet

HOLE DIAMETER (BIT SIZE)
 From To
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>1.88</u>		

Perforations:
 Type perforation MILLS KNIFE
 Size perforation 3/8" x 2"

From 0 feet to 73 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 4-7-05 19____
 Date completed 4-9-05 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 19' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Davis Drilling and Pumps Contractor
 Address HC 61 Box 54 Hiko NV 89017 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0028966
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191

Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 4-10-05