WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95902
Permit No.
Basin 92A

NOTICE OF INTENT NO. 49263

1. OWNER ROBERT & KOYYA PUGH
MAILING ADDRESS 10575 MIZPAH CR
RENO, NEVADA 89506

ADDRESS AT WELL LOCATION SAME

2. LOCATION NE ¼ SW ¼ Sec. 25 T 21 N/S R 18 E WASHOE County
PERMIT NO. (Issued by Water Resources) | 86-340-10 (Parcel No.) | SILVER KNOLLS (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DARK BROWN/CLAY		0	50	50
MEDIUM BROWN/CLAY WITH GRAVEL MIX	60	50	90	40
LIGHT BROWN/ CLAY WITH GRAVEL MIX		90	110	20
BLUE/ CLAY WITH SAND AND GRAVEL MIX		110	120	10

RECEIVED 05 JAN 11 AM 8:15 STATE ENGINEER'S OFFICE

NOTE !
GPS/NAD27 CONUS
11 S 0249832
UTM 4393607

Date started 11-14-2004, 2004
Date completed 12-22-2004, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12-26-2004	20+	4 FEET	8 HOURS

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	120 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	STEEL	.188	0	20
6 5/8	PVC	SDR21 F480	20	120

Perforations:
Type perforation SCREEN
Size perforation 0.65 X 4
From 82 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WILLIAM GEORGE MOSEGAARD (Contractor)
Address 7900 N Virginia St. 21 (Contractor)
RENO, NEVADA 89506
Nevada contractor's license number issued by the State Contractor's Board 53579
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2211
Signed William George Mosegaard (By driller performing actual drilling on site or contractor)
Date 1-12-2005

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627