WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95907
Permit No.
Basin 107

NOTICE OF INTENT NO. 54092

1. OWNER Shirley Murguia (Corze Const.)
MAILING ADDRESS
ADDRESS AT WELL LOCATION 425 Upper Colony Wellington

2. LOCATION NW ¼ NW ¼ Sec. 15 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. Issued by Water Resources | 10-241-03 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	
DG Sand		1	6	
DG Sand Cobble		6	27	
Granite Boulder		27	38	
DG Sand, Clay (Some Cobbles)		38	114	
Gravels, Sand (Some Boulders)		114	300'	

RECEIVED 05 MAR 23 PM 2:02 STATE ENGINEERS OFFICE

Date started 3/1/05, 20
Date completed 3/2/05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45-50		1½ hrs

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 301' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	60' Feet
8 3/4 Inches	60 Feet	300' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	SHC40	20	300
6 5/8	13	1.58	1	20

Perforations:
Type perforation Machine Perf
Size perforation 3/16 x 6 x 5# Design
From 260' feet to 300' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 300 feet

9. WATER LEVEL
Static water level 131' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [illegible] Inc
Contractor
Address P.O. 599
Contractor
S.S. NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature]
By driller performing actual drilling on site or contractor
Date March 14 05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627