

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340.

Log No. 95926
 Permit No. _____
 Basin 153

NOTICE OF INTENT NO. 55013

1. OWNER BARRIK / RUDY HILL MINE ADDRESS AT WELL LOCATION 2 1/2 MILES W. ON HWY 50, 1 MILE S. OF HWY 50 RUDY HILL MINE
 MAILING ADDRESS P.O. BOX 676 EUREKA NV. 89316

2. LOCATION SR 1/4 SE 1/4 Sec 10 T 19 N/S R 53 E EUREKA County
 PERMIT NO. WAIVER W-563-A 72209-12
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. WELL PW-3 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	5' 8"	5'
INTERBEDDED MEDIUM GRAINED AND LAMINATED SILTY LIMESTONE		5'	815'	810'
1/4" GRAVEL PAC		815'	160'	655'
(4) SUPER SAC APPROX 1 CUBIC YARD				
3/4 DRAGONITE CHIP (1) SUPER SAC APPROX 1 CUBIC YARD PER BAG		160'	64'	96'
NEAT CEMENT (40) 94 LB BAGS OF PORTLAND		64'	14'	50'

8. WELL CONSTRUCTION
 Depth Drilled 815' Feet Depth Cased 815' Feet

HOLE DIAMETER (BIT SIZE)
 From 12' Inches To 815' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8"</u>		<u>.025</u>	<u>429'</u>	<u>+1</u>

Perforations:
 Type perforation VERT SHOT
 Size perforation 1/8 GLOT
 From 815' feet to 429' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 14' to 64' Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 815' feet to 160' feet

Date started 3-1-05, 20____
 Date completed 3-9-05, 20____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>180'</u>	<u>20</u>	<u>12/18/05</u>

RECEIVED

9. WATER LEVEL
 Static water level 160' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EKLUND DRILLING Contractor
 Address 605 UNION PACIFIC WAY ELKO NV. P.O. BOX 2748, 89903 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698

Signed Jayne Harris
 by driller performing actual drilling on site or contractor
 Date 3-9-05