

Log No. 45929

Permit No. _____

Basin 53

NOTICE OF INTENT NO. 55005

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.348

1. OWNER BARRICK/Ruby Hill Mine ADDRESS AT WELL LOCATION 2 1/2 miles west on Hwy 50; 1 mile south off Hwy 50 at Ruby Hill Mine
 MAILING ADDRESS PO Box 676 Eureka NV 89316
 2. LOCATION SE 1/4 NW 1/4 Sec 9 T. 19 N/S R. 53 E. Eureka County
 PERMIT NO. 55005 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. RIB-P23 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>gravel</u>		<u>0</u>	<u>325</u>	<u>325</u>
<u>2 super sacks of 4 washed gravel</u>		<u>25</u>	<u>325</u>	<u>300</u>
<u>14 bags of 4lb cement - powdered</u>		<u>25</u>	<u>0</u>	<u>25</u>

8. WELL CONSTRUCTION
 Depth Drilled 325 Feet Depth Cased 325 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 3/4 Inches To 20 Feet
 From 6" Inches To 325 Feet
 From _____ Inches To _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.156</u>	<u>0</u>	<u>20</u>
<u>2"</u>		<u>.156</u>	<u>20</u>	<u>325</u>

Perforations:
 Type perforation slotted
 Size perforation 1/2"
 From 25 feet to 325 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 25' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 25 feet to 325 feet

9. WATER LEVEL
 Static water level did not contact water feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started Feb 07 2005
 Date completed Feb 08 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>12-2-25</u>	<u>05:15</u>
	<u>RECEIVED</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eklund Drilling Co Contractor
 Address 605 Union Pacific Way Contractor
Elko NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 003 0823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2262
 Signed Frank Stephens
 By driller performing actual drilling on site or contractor
 Date 02/08/05