COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95930
Permit No.
Basin 101
NOTICE OF INTENT NO. 53106

1. OWNER CASEY PROPERTIES
MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5775 DILLON
FALLON, NV 89406

2. LOCATION NW ¼ NW ¼ Sec 20 T 19 N R 28 E CHURCHILL County

PERMIT NO. | Issued by Water Resources | 008-172-10 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	9	8
BROWN CLAY		9	13	4
BROWN SAND		13	30	17
GRAY SAND		30	60	30
GRAY CLAY		60	70	10
GRAY SAND		70	80	10
BROWN CLAY		80	82	2
BROWN SAND		82	95	13

RECEIVED
MAR 21 2005
DIVISION OF WATER RESOURCES
STATE ENGINEER'S OFFICE

Date started FEBRUARY 12, 20 05
Date completed FEBRUARY 12, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION

Depth Drilled 95 Feet Depth Cased 95 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	95 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	95

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 87 feet to 91 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 22' feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date MARCH 15, 2005

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com