WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95935
Permit No.
Basin 107

NOTICE OF INTENT NO. 54093

1. OWNER Wilber Meddalo / Doug Fleck
MAILING ADDRESS P.O. Box 141 Wellington NV
ADDRESS AT WELL LOCATION 532 Upper Colony

2. LOCATION SW ¼ NE ¼ Sec. 10 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. ____ Issued by Water Resources | 009-191-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand / Soil		1	6	
Sand Gravel		6	25	
~~Sand~~ Clay		25	36	
DG Gravel Sand		36	123	
Some Cobbles		123	164	
DG Clay		164	185	
Grey Clay		185	223	
DG Clay Sand		223	242	
DG Gravels		242	300	

RECEIVED
05 MAR 15 AM 10:46
STATE ENGINEERS OFFICE

Date started 3/3/05, 20
Date complated 3/7/05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	60 Feet
8 3/4 Inches	60 Feet	300 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	SH 40	20	300
6 5/8	1.88	Steel	1	20

Perforations:
Type perforation Machine Perce
Size perforation 3/16 x 6" x 5 rows per ft
From 260 feet to 300 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 300 feet

9. WATER LEVEL
Static water level 103 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jason Drilling Inc
Contractor
Address PO. 599
Contractor
SS NV 89425
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed ____
By driller performing actual drilling on site or contractor
Date March 14 05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627