WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340.

OFFICE USE ONLY
Log No. 95937
Permit No.
Basin 179

NOTICE OF INTENT NO. 34291

1. OWNER RAY BICK
MAILING ADDRESS HC 33, BOX 33810
ELY, NV 89301

ADDRESS AT WELL LOCATION LOT 2

2. LOCATION NE 1/4 SW 1/4 Sec. 29 T 21N N/S R 64E E WHITE PINE County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	8	8
SOFT BROWN SANDSTONE		8	80	72
CEMENTED GRAVEL		80	115	35
SAND & GRAVEL	X	115	118	3
CEMENTED GRAVEL		118	125	7
SAND & GRAVEL	X	125	139	14

RECEIVED
05 MAR 14 AM 10:58
STATE ENGINEERS OFFICE

Date started 3/8/2005, 19__
Date completed 3/9/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
120		~~5.5~~	5.5

8. WELL CONSTRUCTION
Depth Drilled 139 Feet Depth Cased 139 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	139	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	119
6	SRD17		119	139

Perforations:
Type perforation SCREEN
Size perforation .050
From 99 feet to 139 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [ ] Pumped [X] Poured
Gravel Packed: [X] Yes [ ] No
From 51 feet to 139 feet

Seal Type:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
Bentonite Grout

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 72 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING
Contractor
Address P.O. BOX 525
Contractor
ELKO NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed
By driller performing actual drilling on-site or contractor
Date 3/10/2005

USE ADDITIONAL SHEETS IF NECESSARY