WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95939
Permit No.
Basin 191

NOTICE OF INTENT NO. 34289

1. OWNER LANE SHELTON
MAILING ADDRESS BOX 69
MONTELLO, NV 89380

ADDRESS AT WELL LOCATION CLOVER ACRES
Lot 64 Unit 1

2. LOCATION NW 1/4 NW 1/4 Sec. 11 T 37N N/S R 69 E ELKO County
PERMIT NO. (Issued by Water Resources) 011-001-064 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LIGHT TAN COLORED BLAY		0	106	106
LOOSE GRAVEL		106	109	3
CLAY		109	112	3
LOOSE GRAVEL	X	112	115	3
CLAY		115	118	3

RECEIVED
05 MAR 14 AM 10:58
STATE ENGINEERS OFFICE

Date started 2/12/2005 , 19__
Date completed 2/13/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	60		4.5

8. WELL CONSTRUCTION
Depth Drilled 118 Feet Depth Cased 118 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	118	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	18
6	SDR17		18	118

Perforations:
Type perforation SCREEN
Size perforation .050
From 98 feet to 118 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Bentonite Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 118 feet

9. WATER LEVEL
Static water level 72 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 3/9/2005

USE ADDITIONAL SHEETS IF NECESSARY