WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95940
Permit No. 71229
Basin 179

NOTICE OF INTENT NO. 34290

1. OWNER CHERRY CREEK WATER DIST
MAILING ADDRESS HC 33, BOX 33810
ELY, NV 89301

ADDRESS AT WELL LOCATION CHERRY CREEK TOWNSITE

2. LOCATION ~~SW~~ NE 1/4 ~~NE~~ SE 1/4 Sec. 31 T 24N N/S R 63 E WHITE PINE County
PERMIT NO. ~~409335~~ 71229 (W) Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		0	3	3
COBBLED CLAY		3	28	25
HARD PAN		28	46	18
CEMENTED COBBLES		46	275	229
LOOSE ROCK	X	275	276	1
CEMENTED COBBLE		276	305	29
LOOSE ROCK	X	305	307	2
CEMENTED COBBLE		307	352	45
LOOSE ROCK	X	352	355	3

RECEIVED
05 MAR 14 AM 10:58
STATE ENGINEERS OFFICE

Date started 3/4/2005, 19__
Date completed 3/8/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	60		6.5

8. WELL CONSTRUCTION
Depth Drilled 355 Feet Depth Cased 355 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	355	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	18
6	SDR17		18	355

Perforations:
Type perforation SCREEN
Size perforation .050
From 255 feet to 315 feet
From 315 feet to 355 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 355 feet

9. WATER LEVEL
Static water level 230 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 3/10/2005

USE ADDITIONAL SHEETS IF NECESSARY