COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95944
Permit No.
Basin 105

NOTICE OF INTENT NO. 53550

1. OWNER JERRY PALMER CONSTRUCTION
MAILING ADDRESS 1760 BUCKTHORN CT
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 1635 NORTH STAR CT
GARDNERVILLE, NV 89410

2. LOCATION NE ¼ NE ¼ Sec 26 T 13 N R 20 E DOUGLAS County
PERMIT NO. SW SE (Issued by Water Resources) 1320-26-002-036 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
HARD PAN CLAY		3	9	6
COURSE DG GRAVELS		9	45	36
BROWN CLAY		45	110	65
SMALL OBSIDIAN GRAVELS		110	162	525
BROWN GUMMY CLAY		162	203	41
FRACTURED GRAVELS SMALL SILTY SAND LAYERS	XXX	203	240	37

RECEIVED 05 FEB 25 AM 11:39 STATE ENGINEERS OFFICE

Date started 1/31, 20 05
Date completed 2/2, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	65	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	240

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 240 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M 25 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, N V89410
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 2/10/05

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429