

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52512

1. OWNER Lyle + Susan Lemaire ADDRESS AT WELL LOCATION 1140 Allen Road  
 MAILING ADDRESS PO Box 545 Battle Mtn, NV 89820  
 2. LOCATION 1/4 Parcel 4 - King map # 231066 15 T 32 NS R 44 Lander County  
 PERMIT NO. 010-260-32 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	35	35
<del>Blue</del> Brown Clay		35	55	20
Blue Clay		55	95	40
Brown Clay		95	105	10
Sand		105	130	25
Clay Brown		130	160	30
Course Sand + Fine Gravel	-	160	180	20
Brown Clay		180	205	25
Course Gravel + Sand	-	205	240	35

N 40° 30' 174  
 W 116° 59' 985  
 Elevation 4575

RECEIVED  
 05 FEB 25 AM 11:41  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 238 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>10</u>	<u>1 8/8</u>	<u>±1</u>	<u>20</u>
<u>6.625</u>	<u>4.06</u>	<u>1.316</u>	<u>20</u>	<u>238</u>

Perforations:  
 Type perforation Screen  
 Size perforation .050  
 From 200 feet to 238 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 48'  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 48' feet to 238 feet

9. WATER LEVEL  
 Static water level 60' feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fred Anderson Drilling Contractor  
 Address 10760 Grass Valley Rd Winn NV 89445 Contractor  
 Nevada contractor's license number 021467  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053  
 Signed Ch. K... By driller performing actual drilling on site or contractor  
 Date February 23, 2005

Date started Feb. 18 2005  
 Date completed Feb. 20 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>45</u>	<u>3</u>	<u>3</u>