WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95950
Permit No.
Basin 177

NOTICE OF INTENT NO. 34283

1. OWNER CLIFF TEEL
MAILING ADDRESS HC 60-205
WELLS, NV 89835

ADDRESS AT WELL LOCATION 18 MILES SOUTH OF WELLS, NEVADA

2. LOCATION NE 1/4 NW 1/4 Sec. 35 T 35 N/S R 62 E ELKO County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		0	2	2
CLAY		2	8	6
SAND & GRAVEL	X	8	68	60
CLAY		68	106	38
SOFT LOOSE SANDSTONE	X	106	120	14

RECEIVED
05 FEB -2 AM 11:47
STATE ENGINEERS OFFICE

Date started 1/25/2005, 19__
Date completed 1/27/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	30		12

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	19
6	SDR-17		19	120

Perforations:
Type perforation SCREEN
Size perforation .050
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [X] Poured
Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

Seal Type:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
Bentonite Grout

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89801
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 1/30/2005

USE ADDITIONAL SHEETS IF NECESSARY