REPORT NO. A04.109

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 95967
PERMIT NO.
BASIN 84
NOTICE OF INTENT NO. 52117

1. OWNER Chico McCauley
MAILING ADDRESS 6400 Peak Rd. Reno, NV 89506
ADDRESS OF WELL 6400 Peak Rd.
Reno, NV 89506

2. WELL LOCATION SW 1/4 NE 1/4 SEC. 2 T 22 R 20 E Washoe COUNTY
PERMIT NO PARCEL NO 76-120-22 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS

RECEIVED
05 JAN 10 AM 1:22
STATE ENGINEERS OFFICE

Notes: **Pumped 6.75 yards neat cement from 400' to surface. RSRM ticket # 14188. Cut Casing off below ground level. See letter dated 6/21/04 from Tom Gallagher regarding waived perforating requirement.**

Date Started 12/16/04 Date Completed 12/16/04

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)

8. WELL CONSTRUCTION
Depth Drilled 400 Depth Cased 400

HOLE DIAMETER (BIT SIZE)
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To

PERFORATIONS:
Type Perforation Size Perforation
From Feet to Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From Feet to Feet

9. WATER LEVEL
Static Water Level 152 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2189
Signed
By driller performing actual drilling on site or contractor
Dated December 16, 2004