

HUMBOLDT DRILLING & PUMP CO., INC.

P.O. BOX 592
4675 W. WINNEMUCCA BLVD.
WINNEMUCCA, NEVADA, 89445
(702) 623-5259

Log # ~~20694~~

95971

Dept. of Water Resources
201 S. Fall Street
Carson City, Nev 89701

RE: Permit #30673
SW $\frac{1}{4}$, NE $\frac{1}{4}$, S. 12, T. 25, R. 42

April 20, 1987

Dear Dick:

Please find the following information on the abandonment of the above mentioned well permit.

ABANDONMENT:

420 ft. of pipe pulled, re-drilled to 600 ft. Due to poor eelog, mud was placed from 602 ft. up to 60 ft. Cement placed from 60 ft. to 10 ft., then topped off with dirt to the surface.

Driller on site: James Choate #1448.

Sincerely,

Brad Santucci

Brad L. Santucci X
Drilling Division

BLS:tt
Attach.