REPORT NO. A05.026

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 96000
PERMIT NO.
BASIN 103

NOTICE OF INTENT NO. 54971 54971

1. OWNER J. T. Smith
MAILING ADDRESS 10 1/2 Harbor Rd. Dayton, NV 89403
ADDRESS OF WELL Hwy 341
Silver City, Nevada

2. WELL LOCATION NE 1/4 SW 1/4 SEC. 9 T 16 R 21 E Lyon COUNTY
PERMIT NO PARCEL NO 016-101-14 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Dirt & Volcanic Rock		0	4	4
Volcanic Rock		4	55	51
Multi Colored Volcanic Rock	X	55	137	82

RECEIVED
05 APR -4 PM 12:18
STATE ENGINEERS OFFICE

Notes: Lat: N 39 15.828
Long: W 119 38.060

Date Started 3/18/05 Date Completed 3/24/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1Hr.

8. WELL CONSTRUCTION
Depth Drilled 137 Depth Cased 137

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 137 Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	137

PERFORATIONS:
Type Perforation FAC SAW Size Perforation 3/32 X 3
From 117 Feet to 137 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 137 Feet

9. WATER LEVEL
Static Water Level 70 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981
Signed Roger M Thiel
By driller performing actual drilling on site or contractor
Dated March 24, 2005