WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96002
Permit No.
Basin 176

NOTICE OF INTENT NO. 55266

OWNER Tony Lillak
MAILING ADDRESS HC 60, Box 10
Ruby Valley, NV 89833

ADDRESS AT WELL LOCATION Lot 4B, Shanty Town
4B on NOI

2. LOCATION NW 1/4 SW 1/4 Sec. 1 T 26N N/S R 57E E Elko County
PERMIT NO. Issued by Water Resources
006-45A-051 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	2	2
Cobble		2	28	26
Hard Limestone		28	29	1
Brown Clay		29	54	25
Hard Limestone		54	105	51
Fractured Limestone	X	105	109	4
Hard Limestone		109	132	23

RECEIVED
05 APR -4 AM 10:25
STATE ENGINEERS OFFICE

Date started 3/17/2005 , 19__
Date completed 3/18/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
approx	26		4.5

8. WELL CONSTRUCTION
Depth Drilled 132 Feet Depth Cased 132 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	132	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	22
6	SDR-17		22	132

Perforations:
Type perforation screen SDR-17
Size perforation .050
From 102 feet to 132 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [ ] Pumped [X] Poured
Gravel Packed: [X] Yes [ ] No
From 51 feet to 132 feet

Seal Type:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
Bentonite Grout

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality cold

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sharel C. Fertig Sr., dba Fertig Drilling Co
Contractor
Address P.O. Box 525
Contractor
Elko, Nevada 89801
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed Sharel C. Fertig Sr
By driller performing actual drilling on-site or contractor
Date 3/20/2005

USE ADDITIONAL SHEETS IF NECESSARY