WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96013
Permit No.
Basin 91

NOTICE OF INTENT NO. 53973

1. OWNER Bill Morrill
MAILING ADDRESS P.O. Box 770
Verdi, NV 89439

ADDRESS AT WELL LOCATION 350 Riverdale Circle

2. LOCATION SW 1/4 NW 1/4 Sec. 8 T 19N N/S R 18E E Washoe County
PERMIT NO. | Issued by Water Resources | 38-695-07 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the old well. Original log #39396. Aqua deepened from 305 to 540 but lost their drill collar and well filled in with native material to 475. Well had perforations from 455-475 and 265-285. Static was 341 when last checked. Tom Gallagher waived additional perforations. We pumped 5 cu. yards of neat cement mixed 5.2 gal/sack from bottom to top. We then cut the top two feet off of the well casing.				
Washoe Co. Permit #040245				

RECEIVED
05 APR -5 AM 11:57
STATE ENGINEERS OFFICE

Date started 3/31/2005 , 19__
Date completed 3/31/2005 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 540 Feet Depth Cased 475 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	305	Feet	575	Feet
?	Inches	0	Feet	305	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	305
5	10.79	.188	285	475

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 265 feet to 285 feet
From 455 feet to 475 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 341 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 4/1/2005

USE ADDITIONAL SHEETS IF NECESSARY