

Log No. 96018  
 Permit No. \_\_\_\_\_  
 Basin. 108

PRINT OR TYPE ONLY  
 NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50788

1. OWNER Paute Tribe ADDRESS AT WELL LOCATION MW14  
 MAILING ADDRESS 171 Campbell Ln.   
Verington, NV 89447

2. LOCATION 089° 03' 45.7" N 119° 12' 04.02" W LYON County  
 PERMIT NO. SE NE Reservation Trust sec 20 14N 25E  
 Issued by Water Resources Parcel No. Land Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  Cable  Rotary  RVC  Air  Other Auger

6. LITHOLOGIC LOG MW14

| Material            | Water Strata | From      | To         | Thick-ness |
|---------------------|--------------|-----------|------------|------------|
| <u>sandy</u>        |              | <u>0</u>  | <u>10</u>  |            |
| <u>sandy gravel</u> | <u>40</u>    | <u>10</u> | <u>50</u>  |            |
| <u>light gravel</u> |              | <u>50</u> | <u>100</u> |            |

8. WELL CONSTRUCTION  
 Depth Drilled 100 Feet Depth Cased 100 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 100 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>2</u>           | <u>PVC</u>          | <u>sch 40</u>           | <u>0</u>    | <u>100</u> |

Perforations:  
 Type perforation Factory  
 Size perforation 020  
 From 80 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 100 feet

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Andresen Exploration Drilling  
 Address 1635 Bedford rd.   
RENO, NV 89509  
 Nevada contractor's license number issued by the State Contractor's Board 34525  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_

Date started 7/21 2004  
 Date completed 7/21 2004

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>N/A</u> | <u>N/A</u>                    | <u>N/A</u>   |

RECEIVED  
 OCT 9 2004  
 STATE ENGINEERS OFFICE