WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96020
Permit No.
Basin 070

NOTICE OF INTENT NO. 48304

1. OWNER Scott + Julian Barr
MAILING ADDRESS 4635 Jaquilin CT Lot 30
ADDRESS AT WELL LOCATION 4635 Jacqueline Court Winnemucca, NV 89445

2. LOCATION NE ¼ NW ¼ Sec. 17 T 36 N/S R 38 E/W Humboldt County
PERMIT NO. Issued by Water Resources | Parcel No. 010-202-31 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Boulders		0	10	10
Sand		10	15	5
Cobles + Sand		15	160	145
Clay / Brown		160	200	40
Sand / Gravel	✓	200	210	10
Clay		210	215	5
Sand + Gravel	—	215	230	15
Clay		230	235	5

RECEIVED 04 NOV -3 AM 11:17 STATE ENGINEERS OFFICE

Date started Oct 23 2004
Date completed Oct 23 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		4

8. WELL CONSTRUCTION
Depth Drilled 235 Feet Depth Cased 235 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	235 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.06	.316	[illegible]	
			+ [illegible]	235
6.625	10	.188	+ 1	19

Perforations:
Type perforation PVC Screen
Size perforation .032
From 195 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 54
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 54 feet to 235 feet

9. WATER LEVEL
Static water level 92 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson + Sons Drilling (Contractor)
Address 10760 Grass Valley Rd (Contractor)
Winn NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Oct 25-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627