WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirely in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96021
Permit No.
Basin 042

NOTICE OF INTENT NO. ~~[illegible]~~ 34263

1. OWNER KENNETH JOHNS
MAILING ADDRESS BOX 672
WELLS, NV 89835

ADDRESS AT WELL LOCATION no address - 16 miles SW of wells

2. LOCATION ~~SW~~ 1/4 ~~SW~~ 1/4 Sec. ~~34~~ 2 T ~~38N~~ 35 N/S R ~~62E~~ 61 E · ELKO County
PERMIT NO. NE SE (Issued by Water Resources) ~~000-050-010~~ (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COBBLED SUB-SOIL		0	5	5
CEMENTED GRAVEL		5	90	85
BROWN/TAN CLAY		90	100	10
CEMENTED GRAVEL		100	125	25
SAND/GRAVEL	X	125	160	35
SANDSTONE		160	190	30
CEMENTED GRAVEL		190	200	10
FRACTURED BLACK ROCK	X	200	205	5
TAN CLAY		205	240	35

Date started 11/5/2004 , 19__
Date completed 11/10/2004 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	9		12.5

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	160	Feet
6 1/4	Inches	160	Feet	240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	27
6	SDR-17		27	160
4 1/2	SDR-17		160	240

Perforations:
Type perforation MILL SLOT
Size perforation .050
From 120 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 54
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 54 feet to 160 feet

9. WATER LEVEL
Static water level 92 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 12/13/2004

USE ADDITIONAL SHEETS IF NECESSARY