

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27012

1. OWNER Salvador Martinez ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6024 Black Gold St. W. Amargosa Farm Rd.
N. Las Vegas, NV 89031 Amargosa Valley, NV 89020
 2. LOCATION SW 1/4 NW 1/4 Sec. 15 T. 16 N. 48 E. NYE County
 PERMIT NO. 19-661-14 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel w. sand		0	80	80
sand w. clay layers		80	120	40
gravel	1st	120	135	15
limestone		135	145	10
white clay		145	160	15
gravel w. sand	2nd	160	175	15
limestone		175	185	10
gravel + clay		185	200	15
Bottom of well			200	

DOWNDWR RECEIVED
 APR 22 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>0</u>	<u>200</u>
<u>Surface Protective Casing</u>				
<u>8</u>	<u>Steel</u>	<u>.188</u>		<u>7</u>

Perforations:
 Type perforation Machined
 Size perforation 6R, 1032 Screen
 From 160-120 feet to 140 feet
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

Date started 3/15, 2005
 Date completed 3/16, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Cook Drilling Co Contractor
 Address H.C. 70 Box 543 Contractor
Amargosa Valley, NV 89020
 Nevada contractor's license number issued by the State Contractor's Board 5376-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
 Signed Russ Johnson
 By driller performing actual drilling on site or contractor
 Date 4/14/05