

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 26884

1. OWNER SAM DE ANGELIS ADDRESS AT WELL LOCATION 921 Woodchips  
 MAILING ADDRESS 1301 N. ROYAL AV. PAHRUMP NV. 89060  
 2. LOCATION SW 1/4 SE 1/4 Sec. 18 T. 20 N/S R. 53 E. NYE County  
 PERMIT NO. 036-601-29 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BRN CLAY		0	5'	5'
GRAY CLAY		5	23'	18'
CALICHE		23	25'	2'
GRAY CLAY	X	25	68'	43'
BRN CLAY	X	68	75'	27'
GRAY CLAY	X	95	127'	32'
CALICHE	X	127	129'	2'
BRN CLAY	X	129	140'	11'
LITE BRN CLAY	X	140	160'	20'

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>PVC 5/8" HD</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation 1/2 x 6"  
 From 100 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

DCNR/DWR  
 RECEIVED

APR 20 2005

LAS VEGAS OFFICE

Date started 4-4, 2005  
 Date completed 4-8, 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>5'</u>	<u>1/2</u>

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name LARRY'S WATER WELL SERVICE Contractor  
 Address PO. Box 3392 PAHRUMP NV. 89041 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916  
 Signed Larry Jenkins  
 By driller performing actual drilling on site or contractor  
 Date 4/7/05