

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 96078
 Permit No. 87
 Basin _____
 NOTICE OF INTENT NO. 27939

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Wes Pac Utilities ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 30028 Hunter Lake Elementary School
Reno, NV 89520

2. LOCATION NE 1/4 SW 1/4 Sec. 15 T 19N N/S R 19E E Washoe County
 PERMIT NO. M/O 868-57806 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Gravel		0	15	15
Boulders		15	18	3
Boulders & clay		18	23	5
Boulders		23	60	37
Brown clay		60	62	2
Boulders & clay		62	90	28
Boulders & gravel		90	210	120
See next line		210	240	30
Brown silty clay w/few cobbles & gravel				
Fine gravel w/cobbles		240	260	20
Gray silty clay few cobbles		260	280	20
Fine gravel w/cobbles		280	340	60
See next line		340	350	10
Brown clay w/sand & gravel / cobbles				
Sandy clay w/fine gravel		350	390	40
Fine gravel		390	470	80
Sandy clay		470	480	10
Sandy clay w/fine gravel		480	500	20

Date started 12/5/94 _____
 Date completed 12/12/94 _____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>		<u>6 hrs</u>

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 491 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 500 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+2</u>	<u>139</u>
<u>6 5/8</u>		<u>.188</u>	<u>160</u>	<u>181</u>
<u>6 5/8</u>		<u>.188</u>	<u>223</u>	<u>244</u>

Perforations:
 Type perforation Millslot
 Size perforation 1/8 x 3

From 139 feet to 160 feet
 From 181 feet to 223 feet
 From 244 feet to 286 feet
 From 307 feet to 400 feet
 From 410 feet to 470 feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 101 Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 101 feet to 500 feet

9. WATER LEVEL
 Static water level 49 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Normal °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed _____ By driller performing actual drilling on-site or contractor
 Date see pg 2.

RECEIVED
 DIVISION OF WATER RESOURCES
 DECEMBER 13 1994

