

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA

OFFICE USE ONLY

DIVISION OF WATER RESOURCES

Log No. 96122

WELL DRILLER'S REPORT

Permit No. \_\_\_\_\_

Basin 101

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.110

NOTICE OF INTENT NO. 55242

PRINT OR TYPE ONLY

1. OWNER Art Daniels  
 MAILING ADDRESS 3350 Alcorn Road  
Fallon, NV 89406  
 ADDRESS AT WELL LOCATION Art Daniels  
3330 Alcorn road  
Fallon, NV 89406

2. LOCATION sw  $\frac{1}{4}$  se  $\frac{1}{4}$  Sec 27 T 19 N R 28 E Churchill County

PERMIT NO. R-484 008-431-22  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	15	15
Brown Clay		15	22	7
Brown Sand		22	46	24
Black Clay		46	52	6
Green Clay		52	54	2
Brown Clay		54	72	18
Brown Sand	XX	72	80	8

8. WELL CONSTRUCTION  
 Depth Drilled 80 Feet Depth Cased 80 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 80 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	80

Perforations:  
 Type perforation Saw Cut  
 Size perforation 1/8  
 From 75 feet to 80 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 74  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 74 feet to 75 feet

9. WATER LEVEL  
 Static water level 9 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

Date started 04/06, 20 05  
 Date completed 04/06, 20 05

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			

Name Parsons Drilling Inc  
(CONTRACTOR)  
 Address P.O. Box 1265  
(CONTRACTOR)  
Fallon, NV 89407-1265  
 Nevada contractor's license number 29064  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1758  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 04/21/05

RECEIVED  
 05 APR 28 AM 11:00  
 STATE ENGINEERS OFFICE