WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46135
Permit No.
Basin 92R

NOTICE OF INTENT NO. 53715

1. OWNER Travis Rumbaugh
MAILING ADDRESS 1641 Sonterra Court
Reno, NV 89523

ADDRESS AT WELL LOCATION 9170 RainDance Way
Reno, Nevada 89506

2. LOCATION NE 1/4 SW 1/4 Sec. 11 T 20N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources
552-071-07 Parcel No
Golden Valley Ranches Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	130	130
Rock		130	170	40
D.G.	x	170	248	78
T.D. 248				

RECEIVED 05 APR 25 AM 11:57 STATE ENGINEER'S OFFICE

Date started 4/6/2005, 19__
Date completed 4/8/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	248	1 hour
30	150	1 hour
15	120	1 hour

8. WELL CONSTRUCTION
Depth Drilled 248 Feet Depth Cased 248 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	60	Feet
8-3/4	Inches	60	Feet	248	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.9	.188	+2	248

Perforations:
Type perforation Factory sawed
Size perforation 1/8x3
From 208 feet to 248 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 248 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service Contractor
Address P.O. Box 60130 Contractor
Reno, Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 786
Signed [signature] By driller performing actual drilling on-site or contractor
Date 4/12/05

USE ADDITIONAL SHEETS IF NECESSARY