COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96139
Permit No.
Basin 107

NOTICE OF INTENT NO. 55127

1. OWNER Rodney Dalske
MAILING ADDRESS 4030 67th Street 45
Sacramento, CA 95820

ADDRESS AT WELL LOCATION Rodney Dalske
~~51~~ Mason Pass Road
Yerington, NV 89447

2. LOCATION ne ¼ se ¼ Sec 31 T 14 N R 25 E Lyon ~~Churchill~~ County

PERMIT NO. (Issued by Water Resources) 014-281-~~20~~ 21 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	10	10
Gravel		10	17	7
Sand & Gravel		17	57	40
Brown Clay		57	65	8
Rock		65	140	75
Rock w Clay		140	143	3
Rock		143	190	47
Rock w/Gravel	XX	190	198	8

RECEIVED
05 APR 25 PM 1:26
STATE ENGINEERS OFFICE

Date started 03/24, 20 05
Date completed 03/30, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1

8. WELL CONSTRUCTION

Depth Drilled 198 Feet Depth Cased 198 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	198 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	198

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 153 feet to 198 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 198 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on site or contractor
Date 04/14/05

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com