

OFFICE USE ONLY
 Log No. 96143
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32319

1. OWNER Tommy Thompson ADDRESS AT WELL LOCATION 2215 Deer St Silver Springs NV
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NW 1/4 Sec. 29 T. 17 N/S R. 25 E Lyon County
 PERMIT NO. 17-453-04 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand & Clay</u>		<u>0</u>	<u>60</u>	
<u>Small gravel & Sand</u>		<u>70</u>	<u>90</u>	
<u>gray clay & sand</u>		<u>90</u>	<u>110</u>	
<u>gravel</u>		<u>110</u>	<u>130</u>	
<u>gravel & brown clay</u>		<u>130</u>	<u>150</u>	

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
10 5/8 Inches 0 Feet 150 Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1 8/8</u>	<u>41</u>	<u>20</u>
<u>1 7/8</u>		<u>SDR 20</u>	<u>20</u>	<u>150</u>

Perforations:
 Type perforation Seal
 Size perforation 5/16
 From _____ feet to _____ feet
 From 70 feet to 85 feet
 From _____ feet to _____ feet
 From 115 feet to 125 feet
 From 145 feet to 150 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 80
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 130 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Contractor
 Address BX 599 Silver Springs NV 89429 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0631841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-13-05

Date started 4-12, 20 05
 Date completed 4-13, 20 05

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>304</u>	<u>100 FT</u>	<u>3 HRS</u>

RECEIVED
 05 APR 20 AM 11:08
 STATE ENGINEERS OFFICE