WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 961447
Permit No.
Basin 088

NOTICE OF INTENT NO. 52243

1. OWNER Kelly McInerny
MAILING ADDRESS 3990 Joy Lake Rd.
Reno, NV 89511

ADDRESS AT WELL LOCATION 3990 Joy Lake Rd.

2. LOCATION SE 1/4 SE 1/4 Sec. 10 T 17N N/S R 19E E Washoe County
PERMIT NO. R-490 Issued by Water Resources
154-030-01 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6 5/8" x 192'				
domestci water well by pouring approximately 2.5				
cu. yards of neat cement from top to bottom per				
Tom Gallagher's instructions.				
Washoe Co. Permit #WL040192				

RECEIVED
05 APR 20 AM 11:04
STATE ENGINEERS OFFICE

Date started 4/14/2005 , 19__
Date completed 4/14/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 192 Feet Depth Cased 192 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	192

Perforations:
Type perforation ?
Size perforation ?
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 191 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2159
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 4/15/2005

USE ADDITIONAL SHEETS IF NECESSARY