

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 96160  
 Permit No. \_\_\_\_\_  
 Basin 087

NOTICE OF INTENT NO. 59784

1. OWNER Sierra Machinery ADDRESS AT WELL LOCATION 1651 Glendale Ave Sparks  
 MAILING ADDRESS 1651 Glendale Ave Sparks NV  
 2. LOCATION NE 1/4 SW 1/4 Sec 8 T 19 N R 20 E Washoe County  
 PERMIT NO. M10900-39-04-031 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thick-ness
Well was in good condition.				
Drilled out seal and pulled out casing.				
Pump grouted from 24' to surface.				

8. WELL CONSTRUCTION  
 Depth Drilled 24 Feet Depth Cased 24 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet 24 Feet  
10 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0</u>	<u>24</u>

Perforations:  
 Type perforation Factory  
 Size perforation 020  
 From 10 feet to 24 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 9  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 9 feet to 24 feet

9. WATER LEVEL  
 Static water level 13 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cold °F Quality N/A

Date started 2/24, 2005  
 Date completed 2/24, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>N/A</u>	<u>N/A</u>	<u>02:46:12</u>
			<u>BECEIA</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Andresen Exploration Drilling Contractor  
 Address 1635 Belford rd. Reno, NV 89509 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 34525  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 3/20/05