

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 96170
 Permit No. _____
 Basin 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **49554**

1. OWNER Federal Aviation Administration
 MAILING ADDRESS 55 Broadway, Kendall Square
Cambridge, MA 02142

ADDRESS AT WELL LOCATION Long term parking lot at
Reno/Tahoe Airport

2. LOCATION SW 1/4 NE 1/4 Sec. 19 T 19N N/S R 20E E Washoe County
 PERMIT NO. _____
 Issued by Water Resources T521034 1520131 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned 4, 1" pvc monitor wells and 1, 4" monitor well. We installed a 1/4" air line to the bottom of the 1" wells and blew the water from the well and then filled them with neat cement. We then installed a 1" tremme pipe to the bottom of the 4" well and pumped in neat cement from the bottom of the well to surface. The following day, we removed the traffic boxes and finished with cement to grade. Following are the water levels and depths of the monitor wells.				
PW-1, 4" pvc well, swl - 7.7', depth 18.3'				
MW-1, 1" pvc well, swl - 7.6', depth 19.6'				
MW-2, 1" pvc well, swl - 7.7', depth 19.8'				
MW-3, 1" pvc well, swl - 6.9', depth 19.3'				
4, 1" pvc well, swl - 7.2', depth 17.2'				
5, 1" pvc well, swl - 7.3', depth 17.2'				
we mixed a total of 5 bags of Portland cement and 25 gallons of water to fill these wells.				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased + - 20' Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	To	Feet
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1" and 4'	pvc	sch. 40	0	+ - 20'

Perforations:
 Type perforation _____
 Size perforation _____

From	feet to	feet
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Surface Seal: Yes No Seal Type:
 Depth of Seal 20' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level see comments feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump Contractor
 Address P.O. Box 20159 Contractor
Carson City, NV. 89721
 Nevada contractor's license number issued by the State Contractor's Board 39920
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
 Signed Dan Trampe
 By driller performing actual drilling on-site or contractor
 Date 4/16/2005

Date started 4/5/2005 19
 Date completed 4/5/2005 19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

RECEIVED
 05 APR 18 AM 11:10
 STATE ENGINEERS OFFICE