WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46174
Permit No.
Basin 093

NOTICE OF INTENT NO. 49259

1. OWNER DONALD C & JANET WAITE
MAILING ADDRESS 15705 ELKHORN LN.
RENO, NEVADA 89506

ADDRESS AT WELL LOCATION 15705 ELKHORN LN
RENO, NEVADA 89506

2. LOCATION NW ¼ NW ¼ Sec. 23 T. 22 N/S R. 19 E. WASHOE County

PERMIT NO. (Issued by Water Resources) | 079-470-65 (Parcel No.) | RED ROCK ESTATES(ANTELOPE VALLEY) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY TOP SOIL		0	12	12
D.G LIGHT BROWN		12	65	53
D.G DARK BROWN	65	65	208	143

RECEIVED
05 APR 18 AM 11:11
STATE ENGINEERS OFFICE

Date started 02-8-2005, 2005
Date completed 03-17-2005, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
03-14-2005	22+	6	5

8. WELL CONSTRUCTION
Depth Drilled 208 Feet Depth Cased 208 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	208 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	STEEL	.188	0	10
6 5/8	PVC	SDR 21 F480	10	208

Perforations:
Type perforation SCREEN
Size perforation .065 X 4
From 145 feet to 203 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 208 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WILLIAM GEORGE MOSEGAARD WELL DRILL (Contractor)
Address 7900N Virginia ST #21 RENO NV 89506 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 53579
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2201
Signed William George Mosegaard (By driller performing actual drilling on site or contractor)
Date 04-15-2005

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627