COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96203
Permit No.
Basin 101

NOTICE OF INTENT NO. 55128

1. OWNER Robert Woolsey
MAILING ADDRESS P.O. Box 994
Fallon, NV 8406

ADDRESS AT WELL LOCATION Robert Woolsey
6495 Jacobs Rd
Fallon, NV 89406

2. LOCATION nw ¼ nw ¼ Sec 6 T 19 N R 28 E Churchill County

PERMIT NO. | Issued by Water Resources | 008-071-48 Parcel No | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Brown clay		3	10	7
Brown sand		10	22	12
Gray clay		22	39	17
Gray sand		39	53	14
Black Sand		53	70	17
Gray sand		70	86	16
Black clay		86	98	12
Black sand		98	117	19
Gravel		117	125	8
Gray sand		125	150	25
Gray clay		150	158	8
Gray sand		158	183	25
Brown clay		183	192	9
Brown sand	xx	192	202	10

RECEIVED 05 MAR 28 PM 1:01 STATE ENGINEERS OFFICE

Date started 3/08, 20 05
Date completed 3/09, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1hr

8. WELL CONSTRUCTION

Depth Drilled 202 Feet Depth Cased 202 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	202 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	202

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 197 feet to 202 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 202 feet

9. WATER LEVEL
Static water level 26 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1
Signed Clyde W. M
By driller performing actual drilling on site or contractor
Date 03/24/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com