WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96227
Permit No.
Basin 203

NOTICE OF INTENT NO. 79488

1. OWNER Nevada Department of Transportation
MAILING ADDRESS 1263 South Stewart Street Carson City NV 89712
ADDRESS AT WELL LOCATION Two miles East on Hwy 319 Panaca NV North side of Hwy

2. LOCATION S/W ¼ N/E ¼ Sec. 9 T. 2 N/S R. 68 E. Lincoln County
PERMIT NO. (Issued by Water Resources) N A (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	64	64
Sand-Gravel	X	64	93	29
Clay		93	100	7

This well was clean to original Depth but casing was in poor condition Very large perforation on bottom and 50' cement seal on surface Variance # R 1282 was Granted to me on NAC 534.420 for perforating Installed 3" Tremmie pipe filled with Neat cement cut casing off 12" below surface at top of cement 840 LBS cement and 420 gals water

Date started 4-27-05, 19
Date completed 4-28-05, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DRAWDOWN
RECEIVED
MAY 02 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	100 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		1/4"	0	100

Perforations:
Type perforation torch cut
Size perforation 1/4" x 10"
From 65 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 4-28-05

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627