REPORT NO. A05.032

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

LOG NO. 96274
PERMIT NO.
BASIN 89

NOTICE OF INTENT NO. 54969

OWNER Fred Austin C/O: Jen Menkin-Austin
MAILING ADDRESS 245 Finch Way Washoe Valley, NV 89704
ADDRESS OF WELL 245 Finch Way
Washoe Valley, NV 89704

2. WELL LOCATION NE 1/4 SW 1/4 SEC. 32 T 17 R 20 E Washoe COUNTY

PERMIT NO ____ PARCEL NO 50-395-09 SUBDIVISION NAME ____

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

| MATERIAL | STRATA | FROM | TO | THICKNESS |
|---|---|---|---|---|
| Brown Clay & Black Rock | | 178 | 210 | 32 |
| Gray Clay | | 210 | 215 | 5 |
| Black Clear Green Rock | | 215 | 220 | 5 |
| Black Rock & Granite | | 220 | 240 | 20 |
| Black, Green, Purple Rock | | 240 | 245 | 5 |
| Black Green, Purple Rock & | | 245 | | |
| Red Granite | X | 245 | 250 | 5 |
| Black, Red, Green Granite | X | 250 | 283 | 33 |

RECEIVED
MAY 0 4 2005
STATE ENGINEER'S OFFICE

Notes: See original well log for sanitary seal.
Lat: N 39 17.555, Long: W 119 45.764

Date Started 4/1/05 Date Completed 4/4/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

| | GPM | DRAWDOWN | TIME (HRS) |
|---|---|---|---|
| | 20+ | | 1 1/2Hrs. |
| | | | |
| | | | |

8. WELL CONSTRUCTION

Depth Drilled 283 Depth Cased 283

HOLE DIAMETER (BIT SIZE)
7 7/8 Inches 178 Feet 283 Feet
____ Inches ____ Feet ____ Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

| Size OD | Weight/Ft | Wall Thickness | From | To |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 163 | 283 |
| | | | | |
| | | | | |
| | | | | |

PERFORATIONS:
Type Perforation FAC SAW Size Perforation 3/32 X 3
From 263 Feet to 283 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth ____
PLACEMENT METHOD: [ ] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From ____ Feet to ____ Feet

9. WATER LEVEL
Static Water Level 126 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature ____ F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed [signature]
By driller performing actual drilling on site or contractor

Dated April 4, 2005