

Log No. 96279
 Permit No. _____
 Basin 032

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34861

1. OWNER Albert W. Harrison ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 936 W. Winnemucca Blvd NA
Winnemucca, NV 89445
 2. LOCATION NW 1/4 SE 1/4 Sec 25 T 39 N/S R. 36 E Humboldt County
 PERMIT NO. 05-157-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---------------------------|--------------|------|-----|-----------|
| Top Soil | | 0 | 5 | |
| Sand & Gravel | | 5 | 10 | |
| Brown Clay | | 10 | 25 | |
| gray clay | | 25 | 35 | |
| Decomposed Granite | | 35 | 75 | |
| Brown Clay | | 75 | 85 | |
| Decomposed granite & Clay | | 85 | 105 | |
| Decomposed Granite | | 105 | 265 | |
| Decomposed Granite & Clay | | 265 | 285 | |
| Decomposed Granite | | 285 | 345 | |

8. WELL CONSTRUCTION
 Depth Drilled 345 Feet Depth Cased 345 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 345 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/8</u> | | <u>.188</u> | <u>+1</u> | <u>345</u> |

Perforations:
 Type perforation punched
 Size perforation 4 x 1
 From 180 feet to 345 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 53
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 53 feet to 345 feet

9. WATER LEVEL
 Static water level 9.7 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name American Drilling Contractor
 Address 3040 Callahan St. Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 0020578
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2208
 Signed Cover Bundick
 By driller performing actual drilling on site or contractor
 Date 4-25-04

Date started 4-15, 2004
 Date completed 4-23, 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>150</u> | | <u>6</u> |

RECEIVED
 05 MAY - 3 PM 10:26
 STATE ENGINEERS OFFICE