COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96282
Permit No.
Basin 101
NOTICE OF INTENT NO. 54883

1. OWNER Cornerstone Construction
MAILING ADDRESS 3650 Research Way #22
Carson City, NV 89706

ADDRESS AT WELL LOCATION
3190 Brookside Drive
Fallon, NV 89406

2. LOCATION se ¼ ne ¼ Sec 27 T 19 N R 28 E Churchill County

PERMIT NO. | Issued by Water Resources | 008-421-25 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Brown Sand		15	17	2
Brown Gravel		17	30	13
Brown Sand		30	39	9
Gray Sand		39	42	3
Black Sand		42	51	9
Gray Sand		51	60	9
Brown Sand		60	65	5
Gray Sand		65	79	14
Brown Sand		79	93	14
Gray Clay		93	96	3
Green Clay		96	118	22
Gray Clay		118	124	6
Gray Sand		124	136	12
Black Sand		136	152	16
Brown Sand	XX	152	160	8

RECEIVED
05 MAY -3 PM 10:26
STATE ENGINEERS OFFICE

Date started 2/21, 20 05
Date completed 2/22, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1hr

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	160

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 155 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753 T1
Signed [signature]
By driller performing actual drilling on site or contractor
Date 03/25/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com