



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54741

1. OWNER Ed King Construction ADDRESS AT WELL LOCATION 775 CORRIENTE Ct. Fernley NV
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 NE 1/4 Sec. 15 T 20 N/S R. 24 E Lyon County _____
 PERMIT NO. 21-157-19 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other nut

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Dirt</u>		<u>0</u>	<u>15'</u>	<u>15</u>
<u>Gray clay</u>		<u>15'</u>	<u>35'</u>	<u>20</u>
<u>Clay + Sashed</u>		<u>35'</u>	<u>125'</u>	<u>90</u>
<u>Gravel</u>	<input checked="" type="checkbox"/>	<u>125'</u>	<u>160'</u>	<u>35</u>

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 160' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>Steel</u>	<u>13</u>	<u>.188</u>	<u>7</u>	<u>20</u>
<u>PVC</u>	<u>200</u>	<u>.375</u>	<u>20</u>	<u>160'</u>

Perforations:
 Type perforation Sawed
 Size perforation 4/8 x 4
 From _____ feet to _____ feet
 From 140' feet to 160' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 160'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 160 feet to 160 feet

9. WATER LEVEL
 Static water level 56' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.10 °F Quality Clear

Date started 4-26-05, 20_____
 Date completed 4-26-05, 20_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30 GPM</u>	<u>Air Lift</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc Contractor
 Address P.O. 599 Silver Springs NV 89429 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4/27/05

RECEIVED
 MAY 06 2005
 STATE ENGINEER'S OFFICE



12



